

To,  
M/s KPTL-GULERMAK JV  
Lead Member: M/s Kalpataru Power Transmission Ltd.  
B-5, 4th Floor, Tower – 3, Okaya Centre, Sector -62  
Noida – 201309 (Uttar Pradesh), India  
Tel: 01206742500

Bhopal & Indore Metro General Consultant  
Bhopal SMART City  
1<sup>st</sup> Floor BMC Building  
Sector A, Berkheda  
Bhopal, 462022  
Madhya Pradesh  
India

Date: 15<sup>th</sup> June 2023

**Contract:** “Engineering supply, Erection Testing and Commissioning of Power supply Receiving Sub Station (RSS), Traction Sub-Station (TSS), Auxiliary Sub-Station (ASS), 750V DC Third Rail and SCADA System for Bhopal Metro Rail Project”. LoA No. 1351/ MPMRCL/2022, dated:05.09.2022

**Subject:** **BH-08: Regarding Submission of Revised GA, GTP & MQP of IPS Tube from M/s Alpro Extrusions Pvt. Ltd.**

**Reference:** BH-08-BIG-PST-LTR-000869

**Reference:**

**Communication:** 1) KPTL letter BH-08-KPTL-GUL-PRC-LTR-01067 Dated 14.06.2023  
2) GC letter BH-08-BIG-PST-LTR-000849 dated 10.06.2023  
3) KPTL letter BH-08-KPTL-GUL-PRC-LTR-01021 Dated 08.06.2023

**Kind Attention:** Mr. Nikesh Verma (Contractor's Representative)

Dear Sir,

In reference to the letter no. (1) above, M/s KPTL-GULERMAK JV has submitted the Revised GA, GTP & MQP of IPS Tube from M/s Alpro Extrusions Pvt. Ltd.

M/s KPTL has earlier submitted the GA, GTP and MQP of IPS Tube from M/s Alpro Extrusions Pvt. Ltd. vide ref (3). Accordingly, GC has reviewed the submitted technical documents and approved the same vide letter ref (2).

However, M/s KPTL has submitted the revised GTP as there was a correction in the Material Grade of IPS tube. In earlier GC approved GTP, the material grade of IPS tube was **IS 19501M**. After technical discussion with the OEM and M/s KPTL, GC has agreed for the change of material grade designation to **IS 63401 WP (range 2)** which has more Tensile Strength compared to the former grade. Hence, the revised GTP submitted is hereby approved considering the only change in the material grade and GA or other technical particulars remains unchanged which were approved earlier.

Further, the above approval shall not relieve the contractor from responsibilities for complying with the requirements of this contract. Final responsibility lies with M/s KPTL-GULERMAK JV for fulfilling the entire contractual requirements.

Yours Faithfully,



Pankaj Agrawal

**Dy. Project Director (Systems)**

Bhopal Metro Rail Project

**Copy to:** 1. GM (Rolling Stock), MPMRCL

2. Additional Director (Technical), MPMRCL